

**TABLE 1: REMAINING WATER AND WASTEWATER CAPACITY AS OF DECEMBER 31, 2022**

		A	B	C	D = A - (B+C)	E	F = D / E * 1000
		2022 MAX CAPACITY (1000 m <sup>3</sup> /d)	MAX DAY / WEEK PROJECTED FLOW (1000 m <sup>3</sup> /d)	COMMITTED FLOW (1000 m <sup>3</sup> /d)	REMAINING CAPACITY (1000 m <sup>3</sup> /d)	MAX DAY / WEEK FLOWS PER CAPITA (m <sup>3</sup> /d/c)	REMAINING CAPACITY (PEOPLE)
<b>WATER</b>	<b>INTEGRATED URBAN WATER SYSTEM</b>	250.00	177.13	23.35	49.52	0.3201	154,719
	<b>BADEN-NEW HAMBURG</b>	12.61	5.36	0.02	7.23	0.3648	19,811
	<b>AYR WATER SYSTEM (H)</b>	5.53	2.69	1.38	1.46	0.4115	3,557
	<b>WELLESLEY</b>	3.00	1.11	0.00	1.88	0.3027	6,223
	<b>ST. CLEMENTS</b>	1.77	0.50	0.01	1.26	0.4019	3,144

		A	B	C	D = A - (B+C)	E	F = D / E * 1000
		2022 CAPACITY (1000 m <sup>3</sup> /d)	AVERAGE PROJECTED FLOW (1000 m <sup>3</sup> /d)	COMMITTED FLOW (1000 m <sup>3</sup> /d)	REMAINING CAPACITY (1000 m <sup>3</sup> /d)	AVERAGE FLOWS PER CAPITA (m <sup>3</sup> /d/c)	REMAINING CAPACITY (PEOPLE)
<b>WASTEWATER</b>	<b>KITCHENER WWTP</b>	122.70	69.55	10.75	42.39	0.2520	168,214
	<b>WATERLOO WWTP</b>	57.50	41.65	2.08	13.77	0.2663	51,683
	<b>GALT WWTP</b>	56.80	27.95	3.19	25.66	0.3056	83,975
	<b>PRESTON WWTP</b>	16.82	9.37	1.90	5.54	0.3803	14,573
	<b>HESPELER WWTP</b>	9.32	6.10	0.46	2.76	0.2317	11,897
	<b>ELMIRA WWTP</b>	7.80	3.83	1.56	2.40	0.3310	7,263
	<b>BADEN-NEW HAMBURG WWTP</b>	6.90	3.81	0.02	3.08	0.2614	11,769
	<b>AYR WWTP</b>	3.00	1.53	0.80	0.67	0.2365	2,833
	<b>ST. JACOBS WWTP</b>	1.45	0.93	0.23	0.29	0.4347	677
	<b>WELLESLEY WWTP</b>	1.10	0.87	0.00	0.23	0.2340	991