

TABLE 3: COMMITMENTS AS OF DECEMBER 31, 2022

	A			B	C = A x B			
	COMMITMENTS (PEOPLE)			MAX DAY / WEEK FLOWS PER CAPITA (m ³ /d/c)	COMMITMENTS (m ³ /d)			
	DGA	BUA	TOTAL		DGA	BUA	TOTAL	
WATER	INTEGRATED URBAN WATER SYSTEM	56,714	16,229	72,943	0.3201	18,154	5,195	23,348
	BADEN-NEW HAMBURG	5	61	66	0.3648	2	22	24
	AYR WATER SYSTEM	3,343	0	3,343	0.4115	1,376	0	1,376
	WELLESLEY	3	7	10	0.3027	1	2	3
	ST. CLEMENTS	20	0	20	0.4019	8	0	8

	A			B	C = A x B			
	COMMITMENTS (PEOPLE)			AVERAGE FLOWS PER CAPITA (m ³ /d/c)	COMMITMENTS (m ³ /d)			
	DGA	BUA	TOTAL		DGA	BUA	TOTAL	
WASTEWATER	KITCHENER WWTP	34,932	7,738	42,670	0.2520	8,804	1,950	10,754
	WATERLOO WWTP	2,419	5,395	7,814	0.2663	644	1,437	2,081
	GALT WWTP	7,907	2,549	10,456	0.3056	2,416	779	3,195
	PRESTON WWTP*	3,952	74	4,026	0.3803	1,875	28	1,903
	HESPELER WWTP	1,822	181	2,003	0.2317	422	42	464
	ELMIRA WWTP	4,709	8	4,717	0.3310	1,559	3	1,561
	BADEN-NEW HAMBURG WWTP	5	61	66	0.2614	1	16	17
	AYR WWTP	3,343	29	3,372	0.2365	790	7	797
	ST. JACOBS WWTP	466	54	520	0.4347	203	23	226
	WELLESLEY WWTP	3	7	10	0.2340	1	2	2

(A) See Appendix D for a detailed breakdown of committed population from known development

(B) Average of the previous five years. See Section 2.5 and 2.6 for an explanation of the Average/Max Flow Per Capita Per Day in Column 'B'

(C) Column 'A' multiplied by column 'B'

* Preston WWTP commitments include 372 m³/day for the Boxwood Industrial Subdivision